



STATE OF WASHINGTON
DEPARTMENT OF HEALTH
 SOUTHWEST DRINKING WATER REGIONAL OPERATIONS
P.O. Box 47823 Olympia, Washington 98504-7823
TDD Relay 1-800-833-6388

May 30, 2017 Paul Robischon Washington Water Service Company 6800 Meridian Road Southeast Olympia, Washington 98513	Sunwood Lakes Homeowners Association Inc. ID #863043	
	County:	Thurston
	System Type:	Community
	Operating Permit Color:	Green
	Surveyor:	Kay Rottell
	Inspection Date:	May 11, 2017

Thank you and Mike Forsberg for meeting with me to conduct a survey of this water system. Sanitary surveys are the Office of Drinking Water's (ODW) way to inspect public water systems through a field visit. ODW is also able to offer technical assistance to help utilities improve their system operations and ensure that public health is protected.

This report documents the findings of this survey. Deficiencies that need your attention are summarized below. As you correct the items, send me documentation that demonstrates the items have been completed as directed. Include the system name, ID number, and the date the deficiencies were corrected. You can send them to me by e-mail at kay.rottell@doh.wa.gov or by mail at PO Box 47823, Olympia, Washington 98504-7823.

If you are not able to correct these deficiencies, you must submit a Corrective Action Plan by the date assigned describing how and when the work will be completed.

SIGNIFICANT DEFICIENCIES* - NONE FOUND

SIGNIFICANT FINDINGS - BY JULY 14, 2017**

1. Replace the broken lock hasp and secure the well enclosure for Well #5 (S05) against unauthorized entry.

OBSERVATIONS

2. The water system is required to develop and implement a Small Water System Management Program (SWSMP). This document can be a powerful tool for keeping important documents preserved and indexed, and provide you with the information needed to remain in compliance and to protect public health when operations do not go as expected. You do not need to submit the SWSMP to ODW for review and approval at this time, but it should be available for review on request and during your sanitary survey. You can find the guide for your system on our website (DOH Form #331-134).
3. The homeowner's association must establish the legal authority to implement a cross-connection control program (WAC 246-290-490). The first step in developing an effective cross-connection control program is to develop the legal authority to implement your CCC program. Refer to *Cross Connection Control for Small Water Systems* (DOH Publication #331-234) or a certified cross-connection control

specialist for guidance in establishing your authority. There is a list of certified cross-connection control specialists on the ODW website.

4. After you have established the legal authority to implement a cross-connection control program, direct your cross-connection control specialist to conduct a hazard assessment of all service connections. The authority for this must be in your locally adopted CCC ordinance or by-law. Under the direction of your CCS, ensure that the appropriate cross-connection control device is installed on the service line of each high health hazard premises.
5. Source water quality samples are not being taken in the correct location in accordance with WAC 246-290-300 (7). The system is collecting blended water samples; however, the sources are not blended prior to distribution; the wells alternate and pump directly into distribution individually. Source samples must be collected at each source after any treatment prior to distribution.

RECOMMENDATIONS

6. Periodically inspect and clean Wells 3 and 4 enclosures to ensure that the aquifer is protected from contamination and so the wells can be more easily put back online during an emergency.
7. Read customer meters more frequently to identify increases in distribution system leakage and prevent potential property damage due to an unidentified leak.. We recommend at least bi-monthly meter readings.
8. Continue to install blow-offs on all dead-end lines to allow flushing of the entire distribution system. Flushing helps maintain water quality, removes built-up sediment, and allows an operator to respond to an emergency where it is important to get the existing water out of the distribution system as quickly as possible.
9. Flush your distribution system at least once a year. It is important to get settled material out of the pipes, or else it will someday affect water quality and consumer acceptance. If you have elevated iron and manganese or sediment problems, you may need to perform flushing more frequently.
10. Submit a request for a well field designation. The request should include both well logs, inorganic chemical analysis from each well (such as conductivity, total hardness, nitrates, and chlorides), and a schematic showing that the wells discharge through a common pipe with a sampling port prior to distribution.

SYSTEM INFORMATION

This system consists of 360 residential connections with a residential population of 925, and 1 non-residential connection. This system is approved for 438 equivalent residential units (ERU). The system is owned by the homeowners association which contracts with Washington Water Service Company (WWSC) for operations.

This system is served by two groundwater wells, wells 2 and 5, which feed into two 68,000 gallon reservoirs. The distribution system is divided into two pressure zones, the main zone fed directly from the wells and the reservoirs and a small boosted zone, 22 connections, on Incline Drive near the reservoirs. The Incline Drive pressure zone is fed by a booster pump station near the reservoir site.

The system was initially constructed in 1968 to serve Sunwood Lake Division 1. Well 2 was drilled in 1970 to serve Divisions 2 and 3. Wells 3 and 4 were drilled in 1980 and 1991. The finished water reservoirs were constructed in 1982 and 1991. Well 1 was inactivated prior to 1995 but an exact date is unclear. Well 5 was drilled in 2004 due to high levels of iron and manganese and diminishing capacities in wells 3 and 4.

SECTION 1: SOURCE

This system has two active groundwater wells. The wells are located off 80th Avenue behind the fire station. A 1,000 gallon hydropneumatic tank protects the well pumps and is located adjacent to the wells. Water is pumped directly into the distribution system.

Well 2 is a 12-inch diameter well drilled in December 1970 to a depth of 302 feet. The well is cased to 298 feet and screens are located between 291 and 301 feet. The well log does not indicate a surface seal. The static water level at the time of drilling was 35-feet below the ground surface. The well is equipped with two, 7-1/2 horsepower submersible pumps capable of producing 150 gallons per minute, combined.

Well 5 is an 8-inch diameter well drilled in March 2004 to a depth of 300 feet. The well is cased to 289 feet and screens are located between 283 and 298 feet. Static water depth at the time of drilling was 33-feet below the ground surface. The well has an 18 foot bentonite surface seal. The well is equipped with a 15-horsepower submersible pump capable of producing 175 gallons per minute.

Source ID #	Name:	Description:	Ecology Tag #	Listed on WFI	
				Yes	No
S02	Well #2	301 feet deep	ABR129	<input checked="" type="checkbox"/>	<input type="checkbox"/>
S05	Well #5	300 feet deep	AGP645	<input checked="" type="checkbox"/>	<input type="checkbox"/>

WELLHEAD	Source ID #S02		Source ID #S05	
	Yes	No	Yes	No
System has well log	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
*Wellcap sealed	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
*Openings sealed	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
*Vent screened	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Terminates 6" above grade	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
*Protected from flooding	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Source meter	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Pressure gauge	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
**Raw water sample tap	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Check valve	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
**Protected from unauthorized access	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Structure in good condition	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
*Sanitary control area has no unmitigated contaminants	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
**Protected from physical damage	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Frequency of routine site visit	Monthly		Monthly	
Frequency of source meter reading	Monthly		Monthly	

WELL PUMP EQUIPMENT	Source ID #S02		Source ID #S05	
	Yes	No	Yes	No
*Functional and reliable pump and pump controls	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
*Pump control valve or vacuum relief valve with a protected air gap at discharge	NA		NA	
Generator available	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Generator has automatic startup	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Generator fuel source	diesel		diesel	

EMERGENCY SOURCES

Well 1 is located in the area of the active wells. The well is physically disconnected from the distribution system.

Wells 3 and 4 are located on the same site at a different location within the community. They are fenced and disconnected from the distribution system. These wells could be reactivated if necessary; however, they were taken offline due to the poor aesthetic water quality.

ID #	Name:	Description:	Ecology Tag #	Listed on WFI		Disconnected		Inspected	
				Yes	No*	Yes	No*	Yes	No*
S01	Well #1		AGN775	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
S03	Well #3		AGN774	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
S04	Well #4		AGN724	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

The well enclosure’s lock hasp for Well 5 (S05) was broken and the enclosure cannot be locked. This well is not located within the locked fenced area. Replace the broken lock hasp and secure the well enclosure against unauthorized entry.

WWSC has updated the electrical in the well house to connect a portable generator. WWSC has portable generators available to use at the system during power outages.

The well enclosures for Wells 3 and 4 appear to have insect and possible rodent activity. These enclosures should be inspected and cleaned periodically to ensure that the aquifer is protected from contamination and so the wells can be more easily put back online during an emergency.

SECTION 2: DISINFECTION

This system does not have permanent disinfection. The system installed temporary disinfection in 2015 due to two non-acute total coliform violations. WWSC pressure tested and sealed the reservoirs to prevent contamination entering the water system. Disinfection was removed in July 2015.

SECTION 3: OTHER TREATMENTS

This system does not have any treatment.

SECTION 4: DISTRIBUTION SYSTEM

This distribution system consists of a variety of 2, 4, and 6-inch pipe. The water system is generally looped with only one significant dead end line but multiple smaller dead ends in cul-de-sacs. The system has two pressure zones, the main pressure zone and a small boosted pressure zone consisting of 22 connections.

Pressures range from 77 to 32 psi in the distribution system.

FEATURES	Yes	No
Service area and facility map	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Minimum pressure requirements met	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Service meters (reading frequency semi-annually)	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Leak detection program	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Water system leakage (%)	4.8%	
Adequate valving for flushing and pipe repair	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Blow-offs on dead ends	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Routine flushing (frequency as needed)	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Routine valve exercise (frequency <u>every year</u>)	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Customer meters are only read semi-annually because the homeowners association manages billing instead of WWSC. This less frequent meter reading is adequate but leaks in the distribution system and on the customer side of the meter may be more difficult to identify. We recommend reading the customer meters more frequently if the distribution system leakage increases or if significant property damage occurs because a leak was not identified in a timely manner.

WWSC is working to install blow-offs on all dead ends in the system. They are installing a couple of blow-offs each year at the end of the cul-de-sacs.

The distribution system is not currently flushed on any routine basis. We recommend you flush your distribution system at least once a year. It is important to get settled material out of the pipes, or else it will someday affect water quality and consumer acceptance. If you have elevated iron and manganese or sediment problems, you may need to perform flushing more frequently.

The system has two backflow assemblies installed, one on the swimming pool fill line and one on the tennis court irrigation system. These assemblies are both owned by the homeowners association and are tested annually in the spring.

CROSS CONNECTION CONTROL (Community Systems)	Yes	No
System has enabling authority	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ongoing hazard inspections	<input type="checkbox"/>	<input checked="" type="checkbox"/>
High hazards identified	<input type="checkbox"/>	<input checked="" type="checkbox"/>
High hazards protected	NA	
Annual testing	<input checked="" type="checkbox"/>	<input type="checkbox"/>

CROSS CONNECTION CONTROL (Community Systems)	Yes	No
System has installation standards	<input type="checkbox"/>	<input checked="" type="checkbox"/>
CCS on staff or under contract	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Cross connections observed have been eliminated	NA	

The homeowner's association must establish the legal authority to implement a cross-connection control program (WAC 246-290-490). The first step in developing an effective cross-connection control program is to develop the legal authority to implement your CCC program. Refer to *Cross Connection Control for Small Water Systems* (DOH Publication #331-234) or a certified cross-connection control specialist for guidance in establishing your authority. There is a list of certified cross-connection control specialists on the ODW website.

After you have established the legal authority to implement a cross-connection control program, direct your cross-connection control specialist to conduct a hazard assessment of all service connections. The authority for this must be in your locally adopted CCC ordinance or by-law. Under the direction of your CCS, ensure that the appropriate cross-connection control device is installed on the service line of each high health hazard premises.

SECTION 5: FINISHED WATER STORAGE

There are two finished water storage reservoirs installed on Incline Drive. The reservoirs do not have separate inlet/outlets but are equipped with risers and check valves to ensure circulation of the water in the tanks. The inlet/outlet line has a tee with a check valve to allow water to only exit the tank at the bottom when the tank is not filling. During the fill sequence the check valve forces the water to go up the riser to the top of tank.

The reservoirs were pressure tested and resealed to ensure no contamination was entering the reservoir in 2015. The fill risers were raised to the top of the tank to try to prevent stratification and improve mixing in the reservoir at the same time.

RESERVOIR	RESERVOIR NAME	DESCRIPTION	YEAR BUILT	TOTAL VOLUME (GAL)
1	Reservoir 1	14-ft diameter, 60-feet tall Concrete tank	Unknown	68,000
2	Reservoir 2	14-ft diameter, 60-feet tall Concrete tank	1996	68,000

TOP OF RESERVOIR	Res #1		Res #2	
	Yes	No	Yes	No
**Hatch: Locked	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
*Hatch: Watertight seal or gasket	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Hatch: Over-lapping cover	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
*Screened air vent	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
*Openings sealed/protected	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

FEATURES	Res #1		Res #2	
	Yes	No	Yes	No
Separate inlet/outlet	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Protected drain outlet	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
*Protected overflow outlet	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
*Overflow line discharges into a sanitary sewer with an air gap	NA		NA	
Operational water level gauge	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Bypass piping or isolation possibility	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
**Protected from unauthorized entry	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Low level alarms	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Sample tap at outlet	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

MAINTENANCE	Res #1		Res #2	
	Yes	No	Yes	No
Frequency of structural and coating inspection	5 years		5 years	
Frequency of cleaning	5 years		5 years	
Frequency of appurtenance inspection	Semi-annually		Semi-annually	
Frequency of routine site visit	Monthly		Monthly	
**Structure in good condition	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Clear of excessive vegetation	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Thank you for providing pictures of the reservoir hatch, vent, overflow, and other penetrations in the reservoirs.

The reservoirs were last cleaned in 2013.

SECTION 6: PRESSURE TANKS

The system has a 1,000 gallon hydropneumatic tank at the well site to limit water hammer and pump cycling.

Four small pressure tanks are located at the Incline booster pump station to limit booster pump cycling.

Site	Location	# and size of Hydropneumatic Tanks	# and size of Bladder Tanks
1	Wells 2 & 5 pump house	1 – 1,000 gallon	
2	Incline Drive Booster Pump Station		4 – 32, gallon

HYDROPNEUMATIC	Site: 1	
	Yes	No
Pressure relief valve	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Pressure gauge	<input checked="" type="checkbox"/>	<input type="checkbox"/>

HYDROPNEUMATIC	Site: 1	
	Yes	No
Water level sight glass	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Can be isolated	<input checked="" type="checkbox"/>	<input type="checkbox"/>
**Oil less Air compressor	<input checked="" type="checkbox"/>	<input type="checkbox"/>
In good condition	<input checked="" type="checkbox"/>	<input type="checkbox"/>

BLADDER	Site: 2	
	Yes	No
Isolation valve	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Pressure relief valve	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Pressure gauge	<input checked="" type="checkbox"/>	<input type="checkbox"/>
In good condition	<input checked="" type="checkbox"/>	<input type="checkbox"/>

BUILDINGS/ENCLOSURE	Site: 1		Site: 2	
	Yes	No	Yes	No
**Facility secure	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Structure in good condition	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

The hydropneumatic tank pump house is currently being reinsulated. The old insulation has been removed and rolls of insulation were in the pump house but had not yet been installed. Continue the maintenance on the pump house to prevent freezing next winter.

SECTION 7: BOOSTER PUMPS AND FACILITIES

The Incline Drive booster pump station serves the 22 homes near the finished water reservoirs to ensure these homes maintain 30 pounds per square inch (psi) of pressure at the meter. The pumps are alternated: the first call is set at 44/65 psi, second call is set at 42/62 psi, and the third call is set at 40/60 psi.

Facility	Name	Description	Total Capacity (gpm)
1	Incline Drive Booster Pump Station	Three, 1-hp pump	60

BOOSTER PUMPS	Facility 1	
	Yes	No
Number of pumps	3	
Frequency of routine site visit	Monthly	
Isolation valves	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Pressure gauge(s)	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Pressure relief valve	<input checked="" type="checkbox"/>	<input type="checkbox"/>

BOOSTER PUMPS	Facility 1	
	Yes	No
Pump failure alarm	<input type="checkbox"/>	<input checked="" type="checkbox"/>
*Functional pump and pump controls	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Protected from flooding	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Redundant pumps	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Equipment in good condition	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Generator available	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Generator has automatic startup	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Generator fuel source	diesel	

BUILDINGS/ENCLOSURE	Facility 1	
	Yes	No
**Facility secure	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Structure in good condition	<input checked="" type="checkbox"/>	<input type="checkbox"/>

The booster pump station electrical has be rewired to allow a portable generator to be used during prolonged power outages.

SECTION 8: WATER QUALITY MONITORING AND REPORTING

Both wells have elevated levels of manganese above the secondary MCL of 0.05 mg/L. Manganese levels are between 0.11 and 0.13 mg/L. Water quality complaints have decreased since Wells #3 and #4 were taken offline in 2005, which both had high levels of iron and manganese.

Refer to the Water Quality Monitoring Schedule for your monitoring requirements and status. If you have any questions on source monitoring, please contact Sophia Petro at (360) 236-3046.

CHEMICAL	
Sample Point	Description
1	Blended water station at well site

CHEMICAL	Sample Point 1	
	Yes	No
Monitoring adequate	<input checked="" type="checkbox"/>	<input type="checkbox"/>
ODW WQ data reviewed	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Sample collection sites correct	<input type="checkbox"/>	<input checked="" type="checkbox"/>

CHEMICAL	Sample Point 1	
	Yes	No
System has prior:		
<input type="checkbox"/> Nitrate results above 5 mg/L		
<input type="checkbox"/> Nitrite results above 0.5 mg/L		
<input type="checkbox"/> Primary MCL		
<input checked="" type="checkbox"/> Secondary MCL exceedance(s)		
<input type="checkbox"/> Organic detections		
<input type="checkbox"/> Other _____		

This system should not be taking blended samples since the system does not always serve blended water to the customers. The wells alternate and both wells only run during high demand. The system must take discrete samples from source. The wells may qualify for a well field designation. We recommend submitting a request for a well field designation. The request should include both well logs, inorganic chemical analysis from each well (such as conductivity, total hardness, nitrates, and chlorides), and a schematic showing that the wells discharge through a common pipe with a sampling port prior to distribution.

COLIFORM	Yes	No
Monitoring adequate	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Monitoring plan adequate	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Monitoring plan followed	<input checked="" type="checkbox"/>	<input type="checkbox"/>
# of violations since last survey	4	

The system has had 4 non-acute coliform violations since the last survey occurring in November 2012, December 2012, November 2014, and February 2015. After the 2015 coliform violation the reservoirs were pressure tested and resealed.

LEAD & COPPER	Yes	No
Monitoring adequate	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Results below action level	<input checked="" type="checkbox"/>	<input type="checkbox"/>

SECTION 9: SYSTEM MANAGEMENT AND OPERATIONS

The water system is required develop and implement a Small Water System Management Program (SWSMP). This document can be a powerful tool for keeping important documents preserved and indexed, and provide you with the information needed to remain in compliance and to protect public health when operations do not go as expected. You do not need to submit the SWSMP to ODW for review and approval at this time, but it should be available for review on request and during your sanitary survey. You can find the guide for your system on our website (DOH Form #331-134).

PROJECT/PLANNING	Yes	No
System approved	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Current WSP/SWSMP	<input type="checkbox"/>	<input checked="" type="checkbox"/>

PROJECT/PLANNING	Yes No
Year WSP/SWSMP approved	1995
Emergency response plan	<input type="checkbox"/> <input checked="" type="checkbox"/>

REPORTING	Yes No	N/A
WFI reviewed and updated with purveyor	<input checked="" type="checkbox"/> <input type="checkbox"/>	---
Consumer confidence report (Community only)	<input checked="" type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>
Water use efficiency report (Municipal Water Suppliers)	<input checked="" type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>
Cross connection control annual report (> 1000 conn)	<input type="checkbox"/> <input type="checkbox"/>	<input checked="" type="checkbox"/>

OPERATOR CERTIFICATION

This system is required to have one certified operator. The system is operated by Washington Water Service Company (WWSC), an approved Satellite Management Agency. WWSC is responsible for all aspects of the water system except for customer billing. Previously the homeowners association was doing building and yard maintenance, but WWSC has since taken over building and yard maintenance.

If you have any questions or this information is inaccurate, please contact Operator Certification at (800) 525-2536.

Name of Operator	Certification Number	Certifications	Mandatory Operator
Paul Robischon	002434	WDM2, WTPO2, CCS	<input checked="" type="checkbox"/>

WDS-Water Distribution Specialist; WDM-Water Distribution Manager; WTPO-Water Treatment Plant Operator; BTO-Basic Treatment Operator; CCS-Cross Connection Specialist; BAT-Backflow Assembly Tester

OPERATIONS	Yes No
Operational records maintained	<input checked="" type="checkbox"/> <input type="checkbox"/>
Complaints followed up	<input checked="" type="checkbox"/> <input type="checkbox"/>
Complaints documented	<input checked="" type="checkbox"/> <input type="checkbox"/>
# of complaints recorded at ODW (since last survey)	1
Operation and maintenance program	<input checked="" type="checkbox"/> <input type="checkbox"/>
Previous survey deficiencies/findings corrected, if no list below.	<input type="checkbox"/> <input type="checkbox"/>

WWSC is the management company that operates this system and they have a system to track complaints and repairs done on this system. Complaints and records of repairs are kept electronically at the management company.

CLOSING

Your system has had either a total coliform or *E. coli* MCL violation, a treatment technique violation for failure to conduct a required assessment or complete a corrective action, or more than one total coliform monitoring violation since the last survey. Your system does not qualify for the reduced frequency of Sanitary Surveys under WAC 246-290-416 (1).

Your next survey is due in 3 years.

Regulations establishing a schedule of fees, including fees for sanitary surveys, were adopted March 18, 2012 (WAC 246-290-990). The amount due is \$765. An itemized worksheet is enclosed with the invoice.


If you have any questions, please contact me at (360) 236-3037 or by e-mail at kay.rottell@doh.wa.gov.

Sincerely,




Kay Rottell
Office of Drinking Water, Regional Engineer

cc: Tom Thomason, Sunwood Lakes Homeowners Association
Thurston County Environmental Public Health
Denise Miles, ODW



Well #2 (S02)



Well #5 (S05)




Well #5 enclosure with broken lock hasp




Inactive well #1 (S01) to the right of old hydropneumatic tank



Inactive well #3 (S03)



Inactive well #4 (S04)



Hydropneumatic tank and pumphouse at well site



Hydropneumatic tank with pumphouse



Oil-less air compressor in pumphouse



Finished water reservoirs



Catwalk between finished water reservoirs



Incline Drive Booster pump station



Pressure release-valve at BPS



BPS pressure switches



Reservoir sample tap



Combined sample tap at wells #2 and #5



Inactive well #1 (S01)

