



Date Submitted: 2/28/2017

Water Use Efficiency Annual Performance Report - 2016

WS Name: SUNWOOD LAKES HOMEOWNERS

Water System ID# : 86304

WS County: THURSTON

Report submitted by: Carol Bair

Meter Installation Information:

Estimate the percentage of metered connections: 100%

If not fully metered - Current status of meter installation:

Production, Authorized Consumption, and Distribution System Leakage Information:

12-Month WUE Reporting Period: 01/01/2016 To 12/31/2016

Incomplete or missing data for the year? No

If yes, explain:

Distribution System Leakage Summary:

Total Water Produced and Purchased (TP) – Annual Volume	22,261,826 gallons
Authorized Consumption (AC) – Annual Volume	20,092,382 gallons
Distribution System Leakage – Annual Volume TP – AC	2,169,444 gallons
Distribution System Leakage – Percent DSL = $[(TP - AC) / TP] \times 100$	9.7 %
3-year annual average	4.8 %

Goal-Setting Information:

Date of Most Recent Public Forum: 06/10/2011 Has goal been changed since last performance report? No

Note: Customer goal must be re-established every 6 years through a public process

WUE Goals:

Customer Goal (Demand Side):

Install meters on every connection and track water use to establish water reduction goals by 2016.

Describe Progress in Reaching Goals:

Customer (Demand Side) Goal Progress:

System is fully metered

Additional Information Regarding Supply and Demand Side WUE Efforts

Include any other information that describes how you and your customers use water efficiently: